



## INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH TIRUPATI

### CLARIFICATION ON TENDER NUMBER: IISERT/PUR/0547/21

#### **ITEM DESCRIPTION: SUPPLY, INSTALLATION AND COMMISSIONING OF SURVEILLANCE SYSTEMS AT IISER TIRUPATI MAIN CAMPUS YERPEDU.**

REFER OUR TENDER NO: IISERT/PUR/0547/21, DATED:24/12/2021 FOR SUPPLY, INSTALLATION AND COMMISSIONING OF SURVEILLANCE SYSTEMS AT IISER TIRUPATI MAIN CAMPUS YERPEDU.

Pre-Bid meeting was held on January 04th, 2022 at 4:00 Via Google Meet and the minutes of the meeting is as under.

At the outset, the Chairman welcomed all the Members and the representative of the Prospective Bidders briefed, in general, the scope of the Project and thereafter requested Assistant Registrar (S&P) to brief the vendors on the salient features of the commercial terms and the Indenting Officer to read out the clarification sought by the Prospective Bidders and replied thereto as detailed in **Annexure-II & III**

The representatives present were satisfied with the replies given and it was informed that the corrections/additions / clarifications given, as discussed during the Pre-Bid Conference would be hosted on the website of IISER Tirupati and all the Prospective Bidders are required to take cognizance of the proceedings of the Pre-Bid Conference before submitting their bids as stipulated in the Bidding Documents.

The other terms & conditions of the notice issued on our IISER website <http://www.iisertirupati.ac.in/> will remain unchanged. No more correspondence in this regard will be entertained

The meeting ended with a vote of thanks to the Chair

Date:11-Jan-2022

Sd/-  
Deputy Registrar (A&P)



**Annexure-II**

**IISER TIRUPATI  
PRE-BID CONFERENCE FOR SUPPLY, INSTALLATION AND COMMISSIONING OF SURVEILLANCE SYSTEMS AT IISER TIRUPATI MAIN  
CAMPUS YERPEDU  
TECHNICAL QUERIES AND CLARIFICATION**

**TENDER NUMBER - IISERT/PUR/0547/21**

**DATE: 04/01/2022**

<b>Sr. No</b>	<b>Query/Clarification Sought</b>	<b>Clarification / Amendment</b>
1	Request to include bidder / OEM for the point no 12 of page 13 of 101 "The bidder should have successfully installed and commissioned at least one project for any central government/ state government or any central/state PSU or Indian Airports(domestic / International)with 150 cameras along with VMS	Tender specifications amended to  The bidder/ OEM should have successfully installed and commissioned at least one project for any central government/ state government or any central/state PSU or Indian Airports(domestic / International)with 150 cameras along with VMS.  In case the vendor has not done such an installation and if the OEM has done such installation, the OEM representative shall install the VMS at IISER and not the vendor
2	Point no 13 , Page no 31 of 101  The vendor shall indemnify, protect and save IISER, TIRUPATI against all claims, losses, costs, damages, expenses, action suits and other proceeding, resulting from infringement of any law pertaining to patent, trademarks,	Tender specifications amended to:  The vendor shall indemnify, protect and save IISER, TIRUPATI against all claims, losses, costs, damages, expenses, action suits and other proceeding, resulting from infringement of any law pertaining to patent, trademarks, copyrights etc. or such other statutory infringements in respect of all the equipment's and Software supplied by him

	copyrights etc. or such other statutory infringements in respect of all the equipment's supplied by him.									
3	Request to include PAL and NTSC  The network cameras for 720P HD and 1080P HD supplied must meet the SMTPE video standards: SMTPE 296M (HDTV 720p & HDTV 1080P) .	No Change. Original Tender Specifications prevail.								
4	Specifications for the 8 MP varifocal Cameras	Tender specifications amended to:  <table data-bbox="952 845 1680 1013"> <tr> <td>Lens Type</td> <td>Vari Focal</td> </tr> <tr> <td>Focal Length</td> <td>F=2.8 - 12 mm or better</td> </tr> <tr> <td>Aperture</td> <td>F=1.8 or better</td> </tr> <tr> <td>IR Distance</td> <td>30 m / 98.42 Ft or better</td> </tr> </table>	Lens Type	Vari Focal	Focal Length	F=2.8 - 12 mm or better	Aperture	F=1.8 or better	IR Distance	30 m / 98.42 Ft or better
Lens Type	Vari Focal									
Focal Length	F=2.8 - 12 mm or better									
Aperture	F=1.8 or better									
IR Distance	30 m / 98.42 Ft or better									
5	Request to change the specification for Network Protocol : mDNS to DNS	Tender specifications amended to:  Network Protocol mDNS/DNS								



**Annexure III**

**IISER TIRUPATI  
PRE-BID CONFERENCE FOR SUPPLY, INSTALLATION AND COMMISSIONING OF SURVEILLANCE SYSTEMS AT IISER TIRUPATI MAIN  
CAMPUS YERPEDU**

**COMMERCIAL QUERIES AND CLARIFICATION**

TENDER NUMBER - IISERT/PUR/0547/21

DATE: 04/01/2022

Sr. No	Query/Clarification Sought	Clarification / Amendment
1.	Nil	Nil
2.		
3.		
4.		