



INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH TIRUPATI

CLARIFICATION ON TENDER NUMBER – Tender No: : IISERT/PUR/0807/19

ITEM DESCRIPTION- DESIGN, SUPPLY, INSTALLATION AND COMMISSIONING LABORATORY FURNITURE AT NEW CAMPUS YERPEDU.

Refer our Tender No . IISERT/PUR/0807/19 dated 18/03/2020 for Design, Supply, Installation and Commissioning of Laboratory Furniture at New Campus Yerpedu.

Pre-Bid meeting was held on May 04th, 2020 at 14:30 and minutes of meeting is as under.

At the outset, the Assistant Registrar (S&P) welcomed all the Members and the representative of the Prospective Bidders and briefed in general the scope of the project and features of the commercial terms. Thereafter Assistant Engineer (Civil) was asked to read out the clarification sought by the Prospective Bidders and replied thereto as detailed in **Annexure -I**

The representatives present were satisfied with the replies given and it was informed that the corrections / additions / clarifications given, as discussed during the Pre-Bid Conference would be hosted on the website of IISER Tirupati and all the Prospective Bidders are required to take cognizance of the proceedings of the Pre-Bid Conference before submitting their bids as stipulated in the Bidding Documents.

The other terms & conditions of the notice issued on our IISER website <http://www.iisertirupati.ac.in/> will remain unchanged. No more correspondence in this regard will be entertained

The meeting ended with vote of thanks.

04.05.2020

Sd/-
Assistant Registrar (S&P)

IISER TIRUPATI
PRE-BID CONFERENCE FOR DESIGN, SUPPLY, INSTALLATION AND COMMISSIONING LABORATORY FURNITURE AT NEW
CAMPUS YERPEDU.
TECHNICAL QUERIES AND CLARIFICATION

TENDER NUMBER - IISERT/PUR/0807/19

DATE: 04/05/2020

S.No	Reference	Query/Clarification Sought	Clarification / Amendment
1.	BOQ Item No. 1.09	For 6 m wall bench, 2 mtr width 4 under bench cabinets are asked, only 3 are feasible. Please confirm the same. Also for C-frame, stability issue arises for such a length	The no of under bench cabinets have been modified to 3 instead of 4.
2.	BOQ Item No. 6	Request IISER to confirm the scope of VAV system. In BOQ the fume hood is mentioned as Low Constant Volume (LCV) type fume hood. Kindly confirm whether the FH is VAV type or LCV type.	LCV Type

Rest of the specification in the tender remains unchanged.

For GST exemption related queries, please see OM No. 47/2017 Integrated tax dated Nov 14/2017 issued by Ministry of Finance Department Of Revenue

The AutoCAD layout of the Plant science lab & UG lab

https://drive.google.com/drive/folders/1QgzAMGBcSmpkQxH_4lbXv1Sj6WINVJvT

Video of the UG Lab Ground floor and Terrace

https://drive.google.com/drive/folders/1QgzAMGBcSmpkQxH_4lbXv1Sj6WINVJvT

A Document containing the location of tables, Ducted storage cabinet & Fume hood

https://drive.google.com/drive/folders/1QgzAMGBcSmpkQxH_4lbXv1Sj6WINVJvT

