



INDIAN INSTITUTE OF SCIENCE EDUCATION & RESEARCH (IISER) TIRUPATI

(An Autonomous Institution of the Ministry of HRD, Govt. of India)

Transit Campus at Sree Rama Engineering College Building,
Karakambadi Road, Mangalam (B.O), Tirupati - 517 507 ,+91 (0877) 2500 400
www.iisertirupati.ac.in

Name of work & Location : Supply, Installation, Testing and Commissioning of Electrical System To Receive And Distribute Power From HT Line at IISER Tirupati Main Campus, Jangalapalli Village, Yerpadu Mandal, Tirupati


NIT NUMBER : IISERT/Engg/Elec/01 & Corrigendum-I, II

Date of Issue : 23.01.2020

MINUTES OF PRE-BID MEETING

Pre bid Meeting Held at Office of IISER TIRUPATI on 22.01.2020 at 11.00 Hrs

IISER TRUPATI		Representatives of bidders		
1. PV Narayana Rao , SE IISER Tirupati 2. Sivakumar K , AE IISER Tirupati		As per attendance sheet maintained at IISER Tirupati.		
Pre bid Meeting for the above work was held at 11.00 hrs on 22/01/2020 at IISER TIRUPATI in the presence of representative of the intending bidders. The original tender document, terms and conditions including Corrigendum uploaded on website shall stands modified to the extent of modifications defined in this MOM & this MOM shall form part of bid document. Bidders are requested to take note of modifications & submit their bids considering the modifications listed in the MOM and terms and other terms and conditions in the bid document. Soft copies of MOM are uploaded on IISER Tirupati website. The points raised by the intending applicants were discussed and clarified as under.				
Sr No	Ref. to NIT / BOQ	Points Discussed	Query	IISER Tirupati Clarification
1	Volume-III, Financial Bid, BOQ Item No. 1.02	Scope of Work	Transformer conforming to IS -1080 is mentioned in BOQ. Now 1080 revised to 1180 with Level -1 or Level-2 with star rating of the Transformer	Transformer conforming to IS 1180:2014; Level 2. Transformer should be outdoor type , Off load Tap changer
2	Volume-III, Financial Bid, BOQ Item No. 2.01	Scope of Work	Main Panel TTA Type Make lists	TTA Panel OEM(Approved make : Legrand-XL3, Schneider-Blockset, L&T -T-Era, Siemens (Sepan), ABB-MNS). Manufacturing of TTA panel can be done from authorised agencies but OEM has to issue the Test certificate of the panel.
3	Volume-III, Financial Bid, BOQ Item No. 2.03	Scope of Work	Feeder Pillar Item No.2.03 Incomer and outgoing MCCB, MCB breaking capacities to be provide	Feeder Pillar Panel outdoor type free stand mounted with Incomer 125Amps 25kA 4P MCCB- 1 No, Outgoing 63Amps 10kA 4P MCB,32Amps 10kA 4P MCB, 25Amps 10kA SP MCB.


अधीक्षक अभियंता / Superintendent Engineer
भारतीय विज्ञान शिक्षा एवं अनुसंधान संस्थान तिरुपती
Indian Institute of Science Education and Research Tirupati
तिरुपती/ Tirupati - 517507, भारत/ India.

Sr No	Ref. to NIT / BOQ	Points Discussed	Query	IISER Tirupati Clarification
4	Volume-II, Financial Bid, BOQ Item No. 5.1 & 5.2	Scope of Work	Type of Street Light Pole Make list and specification	Street Pole for 6 Mtr & 3.5 Mtr height single arm GI Octagonal pole and thickness of the pole is 3.0mm - Agency has to submit the GA drawing while executing the work. Pole Approved Make - Bajaj/Valmont/Philips/K-Lite
5	Volume-III, Financial Bid, BOQ Item No. 1.01	Scope of Work	HT Panel Manufacturer should be OEM/authorised agency/third party to get in due time	HT panel should be OEM or Authorised agency
6	Volume-III, Financial Bid, BOQ Item No. 2.02	Scope of Work	APFC Panel is TTA Type or PTTA Type and Approved make lists	APFC panel is standard LT panel with CPRI approved . (Make for Heavy Duty Capacitors: EPCOS, L&T, Siemens, Neptune (Ducati), Schneider, ABB).
7	EMD		MSME Exemption against EMD	No Change in Tender condition
8	Power Connection	For Execution	Temporary Power supply	Agency to make their own arrangements.
9	General	Scope of Work	Approval from Electrical Authorities for charging of the system	Scope of work includes obtaining necessary approvals from Electrical Authorities for charging of the Distribution system. Nothing extra will be payable on this account

End of MOM- In total 2 pages.

P. V. S. Rao
(Superintending Engineer)
23/01/2020

अधीक्षक अभियंता / Superintending Engineer
भारतीय विद्यालय शिक्षा एवं अनुसंधान संस्थान तिरुपती
Indian Institute of Science Education and Research Tirupati
तिरुपती/Tirupati - 517507, भारत/India.